

Fire Suppression System Inspection

- _____ Underground fire protection supply mains (Also, see certification checklist for documentation required.)
- _____ Hydrostatic test of sprinkler and standpipe systems (Also, see certification checklist for documentation required.)
- _____ Above ceiling sprinkler piping, hangers, pipe size, etc., and any piping that will be concealed
- _____ Sprinkler types, location, and placement (obstructions)
- _____ Witness fire pump testing per the requirements of NFPA 20 (Also, see certification checklist for documentation required.)
- _____ Standpipe flow test
- _____ Demonstrate water flow from newly installed fire hydrants
- _____ *Final acceptance test and inspection of complete building suppression system (Also, see certification checklist for documentation required.)
- _____ Placement of fire extinguishers (if required)
- _____ Witness Kitchen Hood Suppression system testing, including discharge testing (Balloon test), equipment shutdown, and Nozzle placement
- _____ Witness Special Hazard (Clean Agent) system acceptance testing. This would also include door fan tests.

Other: _____

*To be witnessed by UVA Fire Protection Group prior to demonstration of system to OUBO.
